Measurement and Experiment Specification

Robert Ricci First GENI Measurement Workshop June 26, 2009

set link0 [\$nodeA \$nodeB ...]

```
set link0 [$nodeA $nodeB ...]
```

\$link0 trace

```
set link0 [$nodeA $nodeB ...]
$link0 trace
$link0 trace_type packet
```

```
set link0 [$nodeA $nodeB ...]
$link0 trace
$link0 trace_type packet
$link0 trace_type header
```

```
set link0 [$nodeA $nodeB ...]
$link0 trace
$link0 trace_type packet
$link0 trace_type header
$link0 trace_type monitor
```

```
set link0 [$nodeA $nodeB ...]
$link0 trace
$link0 trace_type packet
$link0 trace_type header
$link0 trace_type monitor
$link0 trace_snaplen 128
```


```
set link0 [$nodeA $nodeB ...]
$link0 trace
$link0 trace_type packet
$link0 trace_type header
$link0 trace_type monitor
$link0 trace_snaplen 128
$link0 trace_expr "ip proto tcp"
```

Transparent Capture

Transparent Capture



Transparent Capture



Measurement capabilities need to be in the RSpec

Resource advertisements help users with component and link selection

Resource advertisements help users with component and link selection

What a slice is allowed to measure will be circumscribed by the definition of the slice

Resource advertisements help users with component and link selection

What a slice is allowed to measure will be circumscribed by the definition of the slice

Describing measurement hardware itself

Resource Selection

- Some users have specific measurement requirements
- ▶ Question: Best level of abstraction?
 - Mark links as "measurable"
 - ▶ Explicitly include devices in topology
 - Dynamic instrumentation

Boundaries

- Duce a user has a slice...
- ► Communication between control framework and measurement service
- **▶** Naming of measurement points

Describing

Measurement Devices

- Likely to be described in different terms than "standard" components
 - Packet rate, capture size
 - Level of protocol decoding
 - > Sampling, summarization ability
- Informing user about devices they may have only implicitly requested

